

pCOWeb changelog

FROM VERSION A1.4.6-B1.2.1 TO A1.4.9-B1.2.4

New Features/Improvements

Block A

- No changes.

Block B

- Clean Bios build with latest development environment.

BACset 2.15

- No changes.

BugFix

Block A

- Fixed an issue when uploading large applications to pCO3.
- Slightly improved shutdown sequence when doing a firmware upload.
- BACnet stack 2.15.1 fixes one more defect spotted during BTL tests on pCOnet.
- BACnet stack version 2.15.2 fixes another defect reported by BTL labs after completing the tests.
- Fixed a formatting issue in e-mails with XML attachments.
- Handled reception of incomplete Modbus TCP/IP packets.

Block B

- Kernel fixes to support new flash JS28F640J3F.
- Fixed rescue mode system information web page, which did not display fully.
- Patched the serial driver to avoid loosing characters when sending packets longer than 16 bytes to pCO.

BACset 2.15

- Fixed error "?Err 0/0 (Device/Other) at Object_Instance" when uploading a .csv backup from a pCOWeb with BACnet stack older than 2.13 to another pCOWeb with stack 2.13 or newer.